



ROWLEY
SPRAYBOOTHs

SPRAY BOOTH AIR CLEARANCE TIME

Aero Smart Booth

THIS RELATES TO THE CLEARANCE TIME OF ISOCYANATES FROM THE AIR AFTER
SPRAYING HAS CEASED.

THE ESTIMATED CLEARANCE TIME FOR THIS SPRAY BOOTH IS:

2 MINUTE(S) 20 SECOND(S)

TEST DATE: 15/05/2026

RE-TEST DATE: 15/05/2027

WARNING:

DO NOT ENTER THE SPRAY BOOTH UNTIL CLEARANCE TIME HAS CEASED

ROWLEY SPRAY BOOTHs MIDLANDS LTD
TEL: 01543 450039
WEB: www.rowleyspraybooths.com
EMAIL: sales@rowleyspraybooths.com



559273